

EQ# 66066203

Certificate of Inspection

HUSKY OIL OPERATIONS LTD.
707 - 8 AVENUE SW
BOX 6525, STN D

CALGARY, AB
T2P 3G7

LOCATION: STEEN RIVER

DESCRIPTION: HORIZONTAL INLET SEPARATOR

COMPANY CODE:

MANUFACTURER: WESTFAB INDUSTRIES LTD.

PREFERRED RE-INSP. INTERVAL: 3.00 Yr.

YEAR BUILT: 2000

CRN: P2754.2

SERIAL #: WF-00-1059

VOLUME: 9.146 M3

HEATING SURFACE:

SURFACE AREA:

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
SHELL	5102 KPA	38 C	-29 C	SV1			TO BE INSTALLED

OWNER INSTRUCTIONS/REMARKS:

CONTACT THE ABSA SAFETY CODES OFFICER BEFORE PLACING THE VESSEL/BOILER IN SERVICE.

VESSEL/BOILER TO BE INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT AND REGULATIONS.

VERIFY THAT VESSEL/BOILER IS PROTECTED BY AN ACCEPTABLE ASME CODE PRESSURE RELIEF VALVE, OF ADEQUATE CAPACITY, SET AT NO MORE THAN MAXIMUM PRESSURE AUTHORIZED AND INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT & REGULATIONS.

Safety Codes Officer: SIMPSON, NORMIN

Signature: 

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.